



भारत का राजपत्र The Gazette of India

असाधारण

EXTRAORDINARY

भाग II—खण्ड 3—उप-खण्ड (ii)

PART II—Section 3—Sub-section (ii)

प्राधिकार से प्रकाशित

PUBLISHED BY AUTHORITY

सं. 1795]

नई दिल्ली, मंगलवार, दिसम्बर 23, 2008/पौष 2, 1930

No. 1795]

NEW DELHI, TUESDAY, DECEMBER 23, 2008/PAUSA 2, 1930

शहरी विकास मंत्रालय

(दिल्ली प्रभाग)

सार्वजनिक सूचना

नई दिल्ली, 23 दिसम्बर, 2008

का.आ. 2958(अ).—दिल्ली के लिए भवन उप-नियम, 1983 में केन्द्र सरकार का निम्नलिखित जिन संशोधनों/उपांतरणों को करने का प्रस्ताव है, उन्हें सार्वजनिक सूचना के लिए एतद्वारा प्रकाशित किया जाता है। यदि किसी व्यक्ति को कोई आपत्ति या सुझाव हों, तो उन्हें इस सूचना के प्रकाशन की तारीख से 30 दिन के अन्दर लिखित रूप में अवर सचिव, दिल्ली प्रभाग, शहरी विकास मंत्रालय, निर्माण भवन, नई दिल्ली-110011 को भेजा जा सकता है। आपत्ति अथवा सुझाव भेजने वाला व्यक्ति अपना नाम और पता भी भिजवाए।

उपांतरण :

खण्ड 17.1 में निम्नलिखित उपांतरण :-

“17.1 भवनों की योजना, डिजाइन और निर्माण इस प्रकार होगा जिससे अग्नि सुरक्षा सुनिश्चित हो और यह भारतीय राष्ट्रीय भवन संहिता की अग्नि सुरक्षा भाग-IV के अनुसार किया जाएगा। ऐसे भवनों (भवन उप नियम सं. 6.2.4.1 में अभिज्ञात) के मामले में भवन योजना मुख्य अग्निशमन अधिकारी, दिल्ली फायर सर्विस द्वारा भी स्वीकृत की जाएगी।”

[सं. के-20013/4/2008-डी डी आई बी]

पी. के. सांन्त्रा, अवर सचिव

MINISTRY OF URBAN DEVELOPMENT

(DELHI DIVISION)

PUBLIC NOTICE

New Delhi, the 23rd December, 2008

S.O. 2958(E).—The following amendments/modifications which the Central Government propose to make in the building Bye-laws, 1983 for Delhi are hereby published for public information. Any person having any objection or suggestion may send the same in writing to the Under Secretary, Delhi Division, Ministry of Urban Development, Nirman Bhawan, New Delhi-110011 within a period of 30 days from the date of this notice. The person making the objection or suggestion should also give his/her name and address.

Modification :

Modify Clause 17.1 as under :—

“17.1 Buildings, shall be planned, designed and constructed to ensure fire safety and this shall be done in accordance with Part-IV Fire Protection of National Building Code of India. In the case of buildings (identified in Bye-laws No. 6.2.4.1), the building schemes shall also be cleared by the Chief Fire Officer, Delhi Fire Service.”

[No. K-20013/4/2008-DDIB]

P. K. SANTRA, Under Secy.